

## ADDITIONS AND MODIFICATIONS TO RFP-GEN-FY13-01

### FOR NEW ROOF

#### Regarding Scope of Work

- 1) All components shall meet UL Class A requirements
- 2) Please add under item #5

Installation shall be done according to best practice standards using ASTM standards.

Mechanically attached roof system will be considered in addition to wind vented system. Mechanically attached systems shall meet or exceed ASTM D5082-99 standards if used.

- 3) Please add under item #6

½ inch high density decking board shall be the equivalent of VERSICO SECURSHIELD HD insulation. It shall contain no wood fibers, pearlite, or expanded polystyrene materials.

Decking material shall meet or exceed all UL requirements regarding fire resistance, wind resistance, uplift resistance, and product performance.

- 4) Please add under item #8

Compression Edge may be substituted for coping, provided it meets ANSI SPRI-ES-1 code requirements for uplift specifications and manufacturer's warranty. An example of acceptable material is Hickman TerminEdge Facia.

- 5) Please add under item #10

New roof shall meet or exceed Factory Mutual's 1-90 wind uplift requirements.

Manufacturer's warranty shall include a NDL (no dollar limit) clause for parts and labor, as well as a 72mph wind rider in the event of wind damage.

- 6) Please add as item #15

No core cuts shall be allowed without written permission from Facilities Superintendent.