

QUESTIONS & ANSWERS REGARDING RFP-GEN-FY13-01

FOR NEW ROOF

Regarding Scope of Work

Q 1) Regarding: item #6

½ inch high density decking board under PVC membrane shall meet or exceed all UL requirements for use of this kind of material. This material shall contain no wood fibers, perlite, or expanded polystyrene materials. It shall be the equivalent of VERSICO SECURSHIELD HD insulation.

Decking material shall meet or exceed all UL requirements regarding fire resistance, wind resistance, uplift resistance, and product performance.

Q 2) Regarding: item #8

Please change .32 White aluminum coping to .032 White aluminum coping

Please note: Compression Edge may be substituted for coping, provided it meets ANSI SPRI-ES-1 code requirements for uplift specifications and manufacturer's warranty. An example of acceptable material is Hickman TerminEdge Facia.